



PPG LABORATORY TEST RESULTS CERTIFICATION

ACID RESISTANCE NITRIC ACID VAPOR

PPG Industries, Inc. certifies the following performance properties for the Duranar® Coil Coating System when applied and baked on properly cleaned and pretreated substrates, according to PPG specifications:

COATING: DURANAR XLE

TEST: AAMA 605.2, test #7.7.3

SPECIFICATION: A coated panel is placed over an eight ounce wide mouth bottle containing 50% full of 70% nitric acid solution at $77 \pm 5^{\circ}\text{F}$ for 30 minutes. The panel is withdrawn, washed with distilled water and allowed to recover for 1 hour before being examined for any effects of significant color change, blisters, and overall appearance.

RESULTS: Slight to no effect visually when compared to an untested area.

May 1, 2002