



PPG LABORATORY TEST RESULTS CERTIFICATION

FLORIDA EXPOSURE CHALK RESISTANCE

PPG Industries, Inc. certifies the following performance properties for the Duranar® Coil Coating System when applied and baked on properly cleaned and pretreated substrates, according to PPG specifications:

COATING: DURANAR XL PLUS

TEST: ASTM D4214 Test Method A-Method D 659: Evaluating Degree of Chalking of Exterior Paints

SPECIFICATION: Wrap black wool felt fabric around the index finger, then apply it with medium pressure to the film under observation. Rotate the finger through an angle of 180°, holding the fabric so it also rotates. Remove the fabric and compare the spot of chalk on it against the photographic reference standards.

RESULTS: After ten (10) years Florida exposure at 45° south, DURANAR® will not chalk greater than No. 8 rating.

May 1, 2002