



## PPG LABORATORY TEST RESULTS CERTIFICATION

### IMPACT RESISTANCE

PPG Industries, Inc. certifies the following performance properties for the Duranar® Coil Coating System when applied and baked on properly cleaned and pretreated substrates, according to PPG specifications:

- COATING:** DURANAR
- TEST:** ASTM D2794-93 - Resistance of Organic Coatings to the Effects of Rapid Deformation (Impact)
- SPECIFICATION:** Factory painted sheet will withstand direct and reverse impact in accordance with ASTM D2794 equal to 3.0 X HDG metal thickness or 1.5 X aluminum metal thickness in mils, expressed in inch pounds.
- RESULTS:** No loss of adhesion when tested using Scotch brand 610 cellophane tape.

May 1, 2002