



## PPG LABORATORY TEST RESULTS CERTIFICATION

### MORTAR RESISTANCE

PPG Industries, Inc. certifies the following performance properties for the Duranar® Coil Coating System when applied and baked on properly cleaned and pretreated substrates, according to PPG specifications:

**COATING:** DURANAR PLUS

**TEST:** AAMA 605.2 Test #7.7.2

**SPECIFICATION:** Mortar mix is prepared in accordance with the AAMA 605.2 specification. Test panel is coated with a 2 inch square pat and placed in a 100% relative humidity cabinet for 24 hours. The mortar is then dislodged and any residue is removed with a damp cloth.

**RESULTS:** There will be no loss of coating film adhesion or visual change in appearance when examined by the unaided eye.

May 1, 2002